



Numerical Study and Simulation in COMSOL Multiphysics of the Dilution Process during Dust's sampling in Dry Machining.

Wenga Ntcheping¹*, Kamguem¹, Kouam¹ and Songmene¹
¹University of Quebec/École de technologie Supérieure/Mechanical engineering/LIPPS
*Corresponding author: 1100, Notre-Dame Ouest Montréal (Québec) H3C 1K3, bernard.wenga@yahoo.ca

Abstract: The importance of dilution's issue during the dust's measurement has risen in recent years with the interests of researchers and engineers working in environmental and occupational safety sector. In fact, the study of machining process recommended adequate devices with best sampling. Furthermore, the excellent measurement of fine and ultrafine particle passed through the dilution of high concentration. The aim of this paper is to propose a numerical study and graphic simulation for the best choice of dilution's issues during dry machining. The constitutive Navier-Stokes equations and CFD k-ε model was used in COMSOL Multiphysics to obtain the graphic simulation of dilution and choice the alternative which was the inlet and outlet in the same iet direction. The experimental setup confirmed the mean of dilution ratio with 95% confidence.

Keywords: Mixing, Simulation, COMSOL Multiphysics, Dilution factor, Dry machining.

1. Introduction

Metallic's particle was considered as the principal responsible of health effects [1, 2] caused by airborne particles in workplace. The quantitative evaluation of fine and ultrafine particle emitted during dry machining was seriously interested by researchers. In 2002, Zimmer &al. have studied the influence of operating parameters on the number-weighted aerosol size distribution in arc welding [3], and grinding [4]. Songmene &al. [5, 6] quantified the PM_{2.5} concentration during drilling for various materials (6061-T6, A356, AZ91E, 70-30 Brass) and different cutting conditions (cutting speed, feed, metal removal rate...). Khettabi &al [7-10] in turning, Zaghbani &al [11] and Kouam &al [12] in milling permitted to evaluate the high level of particle concentration in the experiment. Their works proofed the badly influence of high concentration in the sampling and the maintenance of air quality device (Laser photometer_DUSTTRAK, Aero-dynamic Particle Size Spectrometer_APS, Micro-Orifice-Uniform Deposit Impactor_MOUDI, Electrical Low Pressure impactor_ELPI, Scanning Mobility Particle Sizer_SMPS, Light Detection And Ranging_LIDAR, Condensation Particle Counter_CPC, Differential Mobility Particle Sizer_DMPS) available in the laboratory. These negative phenomena was caused by particle's collision [13-15], particle's leakage lose [16, 17], electrical attraction between particles in motion [18], agglomeration of particles in the pipe [19], aggregation [20], coalescence [21], coagulation [22], condensation and sedimentation [23].

To reduce these effects, the dilution issue was proposed in this study. A simple diluter adapted to the sampling during machining was designed in CATIA V5 and linked in COMSOL Multiphysics to simulate the dilution process. The present paper was organized in six sections: Governing equations; Methods; Theory and numerical model; Experimental results; Discussions; and Conclusion.

2. Governing equations

The Navier-Stokes constitutive equation was used to modeling the fluid transport and the mixing rate. The constitutive equation was composed of continuity equation (eq.1), momentum equation (eq.2), and energy conservation equation (eq.3) [24]:

$$\frac{\partial \rho}{\partial t} + \frac{\partial \rho u_i}{\partial x_i} = 0 \tag{1}$$

$$\frac{\partial \rho u_j}{\partial t} + \frac{\partial \rho u_i u_j}{\partial x_i} = -\frac{\partial P}{\partial x_j} + \frac{\partial \tau_{i,j}}{\partial x_i} + \rho g_j$$
 (2)

$$\frac{\partial \rho \mathcal{H}}{\partial t} + \frac{\partial (\rho \mathcal{H} + P) u_i}{\partial x_i} = + \frac{\partial \tau_{i,j} u_j}{\partial x_i} + \rho g_i u_i - \frac{\partial q_i}{\partial x_i} + S$$
 (3)

Where: \mathcal{H} : total enthalpy per mass unit, S: source of heat, τ_{ij} : viscous stress tensor, g_i : gravity acceleration, q_i : diffusion heat flow, ρ : volumetric mass of the air, P: pressure in the mixture, u_i : displacement





3. Methods

The dilution phenomenon was defined as fluid mechanic problem which could be solved using combined analytical and numerical methods. Generally, it's usually difficult to solve the Navier-Stokes equation modelling the mixing fluid with turbulence. The Computer Fluid Dynamic (CFD) was proposed to solve numerically the problem and simulate it graphically. The 2D or 3D design of diluter was made in CATIA V5 and live-linked in COMSOL Multiphysics [25]. The experimental dilution in COMSOL Multiphysics was used with the following assumptions:

- Inlet boundary conditions were set with the physical geometry of diluter;
- Aerodynamic diameter of particle is less than 2.5μm;
- Properties of the fluid (air) were determined at 25°C with atmospheric pressure;
- -Inlet velocity of pollute and clean air have been imposed by experimental conditions;
- -Fluid was considered incompressible;

4. Theory and numerical model

With the numerical method, the constitutive equation was solved and solution convergence was given with k- ε model [26] represented by the two following equations (eq.4, eq.5): k the turbulent kinetic energy and ε the dissipation rate of turbulent energy.

$$\frac{\partial \rho k}{\partial t} + \frac{\partial \rho k u_i}{\partial x_i} = + \frac{\partial}{\partial x_j} \left[\left(\mu + \frac{\mu_i}{\sigma_k} \right) \frac{\partial k}{\partial x_j} \right] + G_k + G_b - \rho \varepsilon - Y_M + S_k$$
 (4)

$$\frac{\partial p\varepsilon}{\partial t} + \frac{\partial pau_i}{\partial x_i} = + \frac{\partial}{\partial x_j} \left[\left(\mu + \frac{\mu_i}{\sigma_k} \right) \frac{\partial \varepsilon}{\partial x_j} \right] + C_{1\varepsilon} \frac{\varepsilon}{k} (G_k + C_{3\varepsilon}G_b) - C_{3\varepsilon}G_b - C_{2\varepsilon}\rho \frac{\varepsilon^2}{k} + S_{\varepsilon}$$
 (5)

 G_k : kinetics energy due to the velocity gradient; G_b : k energy due to detachment and volume forces; Y_M : contribution of the expansion fluctuation in turbulence for (ϵ); $C_{1\epsilon}$ =1.44, $C_{2\epsilon}$ =1.92, $C_{3\epsilon}$ =0, C_{μ} =0.09; S_k , S_{ϵ} : source terms; σ_k , σ_{ϵ} : turbulent Prandtl number for ϵ and k, σ_k =1, σ_{ϵ} =1.3.

Triangular meshing [27] was applied with 18846 elements and providing 89368 degrees of freedom. The momentum equation was implemented by a stationary nonlinear solver [25] using generalized minimal residual method

(GMRES) was chosen to minimize memory consumption of computer.




Figure 1. Meshing of the diluter in COMSOL

The dilution process was implemented in COMSOL Multiphysics to firstly observe the evolution of the mixing in two alternatives and choose the practical alternative adapted for experiment in workplace.

Secondly, the reason justified the numerical was the location of adequate test in the choice's alternative which was favorable for best dilution.

5. Experimental results

COMSOL Multiphysics permitted to obtain picture of dilution's simulation which could visually analyse by experimenter. The different color of these pictures presented visually the level of dilution. The vortex and the turbulence phenomena were directly observed in the computer screen.





Figure 2. Picture of velocity magnitude simulated in COMSOL during dilution





The singular evolution of the test done in COMSOL Multiphysics, was observed in table1. This table present the test in two alternatives: Alternative «A» presented the situation where the two inlet jets and the outlet flow were in the same direction; Alternative «B» has shown the situation where the two inlet jets were in the opposite direction.

Table 1: Pictures of dilution's process in COMSOL



The different tests have shown that alternative «A» was more excellent in dilution process than alternative «B». The number of vortex directly observed has confirmed this situation of best turbulence in the mixing rate.

6. Discussions

The number of vortex was the principal reason of best dilution because of relaxation's effect during the entrance of two jets (inlet clean air and inlet polluted air) in the cylindrical chamber of diluter. The relaxation and turbulence were due to the wide variation between the small diameter of inlet tube (4 mm) and great diameter of the chamber (40mm). This geometry increased the turbulence and easily mixing air and particle. In addition, the recirculation of flow mixture remains low even when the two inlet speeds are equal. The two-phase of mixture] seems to flow in the chamber so as to obtain the desired

dilution for a possible extent. However, concentration level was represented by the type of color presented (light blue or dark blue). It is quite clear that direct observation of the simulation's picture could help the experimenter in the dilution process. A comparative study was made on both alternatives where alternative «A» presented the best result in the dilution process. In this case, the alternative «A» was chosen by experimenter to validate in the dilution process during dry machining in the workplace.

The dilution process was tested statistically in the workplace where the mean value of dilution factor was obtained with 95% of confidence. This final result was applied with good appreciation during sampling of metallic particle in dry machining.

7. Conclusion

This research's work concerned the numerical study and the simulation of dilution process during dry machining. The CFD k-ε model was used in COMSOL Multiphysics to obtain the graphic simulation of dilution which permitted to choose the best alternative where inlet and outlet test done during dry machining confirmed the simulated mean of dilution factor with 95% confidence. In future work, the dilution models could be discussed and implemented in COMSOL Multiphysics to make a comparison.

8. References

- **1.** Seaton A., MacNee W., Donaldson K., and al., Particulate air pollution and acute health effects, *Lancet*, **Vol.** 345: 176–8, (1995).
- 2. Donaldson K., Stone V., Seaton, A., and al., Ambient particle inhalation and the cardiovascular system: potential mechanisms, *Journal of Environmental Health Perspect.*, Vol. 109: 523–7, (2001).
- **3.** Zimmer A.T., Baron P.A., Biswas P., The influence of operating parameters on the number-weighted aerosol size distribution generated from a gas metal arc welding process, *Journal of Aerosol Science*; **Vol.**33: 519–31, (2002).





- **4.** Zimmer A.T., Maynard A.D., Investigation of the aerosols produced by a high-speed, hand-held grinder using various substrates. *Journal of Ann. Occup. Hyg.*, **Vol.**46: 663–72, (2002).
- 5. Songmene V., Balout B., Masounave J., Clean machining-experimental investigation on particle formation Part I: Influence of machining parameters and chip formation, *Int. Journal of Environmental Conscious Design and Manufacturing*, Vol.14 (1):1–16, (2008).
- **6.** Songmene, V., Balout, B., Masounave, J., Clean machining-experimental investigation on particle formation, PartII: Influence of machining strategies and drill condition, *Int. Journal of Environmental Conscious Design and Manufacturing*, **Vol.**14(1):17–33, (2008).
- 7. Khettabi R., Songmene, V., Masounave, J., and Zaghbani I., Understanding the formation of nano and micro particles during metal cutting, *Int. Journal of signal control and Engineering Application*, Vol.1(3):203-210 (2008).
- **8.** Khettabi R., Songmene V., Zaghbani I., and Masounave J., Modeling of fine and ultrafine particle emission during Orthogonal Cutting, *Int. Journal of Materials Engineering and Performance*, **Vol.**14(1):1-16, (2008).
- 9. Khettabi R., Songmene V., and Masounave, J., Effect of cutting speed, materials and tool geometry on metallic particle emission during orthogonal cutting, *Int. Journal of Materials Engineering and Performance*, Vol. 19(6):767-775, (2008).
- **10.** Khettabi R., Songmene, V., and Masounave, J., Effect of Tool Lead Angle and Chip Formation Mode on Dust Emission in Dry Cutting, *Int. Journal of Material Processing and Technology*, **Vol.**194 (1–3), p 100–109, (2007).
- 11. Zaghbani I., Songmene V., and Khettabi R., Fine and ultrafine particle characterization and modeling in high-speed milling of 6061-T6 aluminum alloy, ASM International, *Int. Journal of Materials Engineering and Performance* (JMEPEG), Vol. 18 (1):38-48, (2009).

- 12. Kouam, J., Songmene, V., Djebara, A., and Khettabi, R., Effect of Friction Testing of Metals on Particle Emission, *Int. Journal of Material Engineering and Performance*, Vol.21(6): 965-972,(2012).
- **13.** Sommerfeld M., and Kussin J., Analysis of collision effects for turbulent gas-particle flow in a horizontal channel-PartI-Particle transport validation, *Int. Journal of Multiphase Flow*, **Vol.** 29: 675–699, (2003).
- **14.** Sommerfeld M., and Kussin J., Analysis of collision effects for turbulent gas-particle flow in a horizontal channel-Part II-Integral properties and validation, *Int. Journal of Multiphase Flow*, **Vol.**29:701–718, (2003)
- **15.** Plumlee H. R., and Semonin R.G., Collision efficiency of charged cloud droplets in electric fields, accepted for publication in *Tellus*, (1965).
- **16.** Hallworth M., Comparing particle losses in transport tubing for instruments with different flowrates, *Particle Measuring Systems*®, Life Science Market Manager, Application Note 80,10p. (2007). (www.pmeauring.com).
- **17.** Hallworth, M., An analysis of acceptable particle losses in transport tubing, *Particle Measuring Systems*®, Life Science Market Manager, Application Note 81, 10p, (2007). (www.pmeauring.com).
- **18.** Qi C., Asbach C., Shin W.G., Fissan H., and Pui D.Y.H., The effect of particle pre-existing charge on unipolar charging and its implication on electrical aerosol measurements, *Journal of Aerosol Science and Technology*, **Vol.**43:232–240, (2009).
- **19.** Hautanen J.; Kilpeläinen M.; Kauppinen, E.L.; Lehtinen, K.; and Jokiniemi, J.; Electrical agglomeration of aerosol particles in an alternating electric field, *Journal of Aerosol Science and Technology*, **Vol.**22:(2):181-189, (1995).
- **20.** Heinson, W.R., Sorensen, C.M., and Chakrabarti, A., Computer simulation of aggregation with consecutive coalescence and non-Coalescence stages in Aerosols, *Journal of Aerosol Science and Technology*, **Vol.** 44, (5): 380-387, (2010).





- 21. Plumlee, H.R., Effects of electrostatic forces on drop collision and coalescence in air, Charged Particle, *Research Laboratory. Rep. No. CPRL-8-64, Grant research, University of Illinois*, Urbana, USA, 101p. (1964).
- **22.** Maisels A., Kruis F.E., and Fissan F.E., Determination of Coagulation Coefficients and Aggregation Kinetics for Charged Aerosols, *Journal of Colloid and Interface Science*, Vol 255:332–340, (2002).
- 23. Roelofs, G.J, and Jongen, S., A model study of the influence of aerosol size and chemical properties on precipitation formation in warm clouds, *Institute for Marine and Atmospheric Research Utrecht (IMAU)*, Utrecht University, Utrecht, Netherlands, 25p. (2004)
- **24.** Violet, P.L., Chabard, J.P., Esposito, P., and Laurence D., Mécanique des fluides appliquées, Presses de l'École Nationale des Ponts et Chaussées, Paris, 66p. (1998).
- **25.** Pryor R.W., Multiphysics Modeling Using COMSOL®: A First Principles Approach, *Jones and Barlett publishers*, LLC, Sudburry, (USA), 852p. (2011).
- **26.** Mekhail, T.A., Aissa, W.A., Hassanein, S.A., and Hamdy, O., CFD simulation of dilute gas-solid flow in 90° square bend, *Journal of Energy and Power Engineering*, **Vol.** 3:246-252, (2011).
- **27.** Crowe C., Sommerfeld M., and Tsuji, Y., Multiphase flows with droplets and particles, *CRC Press*, 286p. (1998).

7. Acknowledgements

The authors would like to acknowledge the financial support of Products, Processes and Systems Engineering Laboratory (LIPPS): located at «École de Technologie Supérieure» / University of Quebec-Montreal Canada.

8. Appendix

Table 2: Numerical test of dilution in COMSOL

| | Alternatives A or B | | | |
|------|---------------------|---------------|------------|---------------|
| Test | Polluted air | | Clean air | |
| | Speed(m/s) | Flow (cc/min) | Speed(m/s) | Flow (cc/min) |
| 1 | 4.5 | | 0.0 | 0.0000000 |
| 2 | | | 0.5 | 3769911.2 |
| 3 | | | 1.0 | 7539822.4 |
| 4 | | | 1.5 | 11309733.6 |
| 5 | | | 2.0 | 15079644.8 |
| 6 | | 33929200.8 | 2.5 | 18849556.0 |
| 7 | | | 3.0 | 22619467.2 |
| 8 | | | 3.5 | 26389378.4 |
| 9 | | | 4.0 | 30159289.6 |
| 10 | | | 4.5 | 33929200.8 |